

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400

TEST REPORT

Client : Basford Brands Pty Ltd
16 - 20 Apparel Close
Breakwater VIC 3219

Test Number : 21-003172
Issue Date : 1/07/2021
Print Date : 1/07/2021

Sample Description Clients Ref : "Rejuvenate"
Sheer woven fabric
Colour : Cloud
End Use : Curtains and Blinds
Nominal Composition : 100% Polyester
Nominal Mass per Unit Area/Density : 170g/m2

AS 1530.2-1993

Methods for Fire Tests on Building Materials, Components and Structures. Part 2: Test for Flammability of Materials

Date Tested	01-07-2021		
Flammability Index	1		
	Length	Width	
Spread Factor	0	0	
Heat Factor	1	1	
Maximum height (d)			
Mean	1.8	1.9	
Coefficient of Variation	78.4	47.1	%
Heat (a)			
Mean	1.5	1.5	°C.min
Coefficient of Variation	10.7	10.7	%
Number of Specimens Tested	9	9	
Observation	Visible smoke.melting,dripping		

These test results relate only to the behaviour of the test specimens of the material under the particular conditions of the test, and they are not intended to be the sole criterion for assessing the potential fire hazard of the material in use.

241504

52502

Page 1 of 1



Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

Fiona McDonald
APPROVED SIGNATORY



MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR